



April 16, 2017

Scott Miller
Remedial Project Manager
Superfund Remedial Branch, Section C
U.S. Environmental Protection Agency, Region 4
61 Forsyth Street SW
Atlanta, GA 30303-8909

VIA EMAIL

Subject: February 2018 Monthly Progress Report

Dear Mr. Miller:

On behalf of Beazer East, Inc. (Beazer), attached is the February 2018 Monthly Progress Report for the Koppers portion of the Cabot/Koppers Superfund Site in Gainesville, Florida. If you have any questions or comments, please contact me.

Sincerely,

A handwritten signature in blue ink, appearing to read 'Gregory W. Council'.

Gregory W. Council, P.E.
Principal Engineer

cc: Kelsey Helton, FDEP
Brandie Stringer, FDEP
Rusty Kestle, USEPA
Robin Hallbourg, ACEPD
Agustin (Gus) Olmos, ACEPD
Kristie Williams, City of Gainesville
Yvette Carter, City of Gainesville
Rick Hutton, GRU
Carrie McCoy, Black & Veatch
Josh Hayes, J.M. Waller
John Herbert, GeoHydro Consultants
Patricia Cline, Community Technical Advisor
Linda Paul, Koppers, Inc.
Mitchell Brouman, TRMI
Mike Slenska, TRMI
Donna Kopach, TRMI
Jim Erickson, Tetra Tech
Wayne Reiber, Cabot Corporation
Steve Clark, FTS
John Helton, FTS
Bryan Cotter, Water and Air Research, Community Technical Advisor
Mark Taylor, Weston Solutions

**FEBRUARY 2018
MONTHLY PROGRESS REPORT
Cabot/Koppers Superfund Site
Gainesville, Florida**

1. Compliance Actions:

- Beazer's Operation and Maintenance (O&M) Contractor performed routine treatment plant O&M services for the groundwater extraction and pretreatment system.
- Remedial Design and Remedial Action activities are presently being conducted.

2. Sampling/Test Results and Data:

- Instantaneous flow rates and totalizer volumes were measured in each extraction well.
- The bi-weekly passive NAPL recovery program continues at Upper Hawthorn monitoring wells and temporary injection points (TIPs) installed as part of the In-Situ Geochemical Stabilization (ISGS) program. Two NAPL recovery events were conducted during the month for the monitoring wells and two were conducted for the TIPs.
- Table 1 provides DNAPL collection data for wells at the Former North Lagoon and Drip Track. The only monitored TIP outside the Former Process Area and Former South Lagoon is at the Drip Track (Table 1). Process Area and South Lagoon recovery data will be included in forthcoming performance monitoring submittals.
- A total of 3,705,648 gallons of groundwater were recovered by the Surficial Aquifer drains and extraction well system (both Surficial Aquifer and UFA) during the past month (system run time of 672 hours). The average recovery rate for the month was approximately 91.9 gallons per minute (gpm). The recovery for each component is listed below.
 - Surficial Aquifer
 - Perimeter Extraction Wells: 508,951 gallons
 - Former North Lagoon Drain: 407,060 gallons
 - Former Drip Track Drain: 456,840 gallons
 - Former Process Area Drain: 447,890 gallons
 - Former South Lagoon Drain: 423,780 gallons
 - Upper Floridan Extraction Wells
 - FW-6: 35,898 gallons
 - FW-21B: 152,081 gallons
 - FW-31BE: 849,440 gallons
 - FW-32BE: 423,708 gallons

Approximately 434.7 million gallons have been recovered from the Surficial Aquifer extraction wells and four drains since the start of the Surficial Aquifer containment system in January 1995.

For the month, the total volume of water treated and discharged to the GRU wastewater system was measured to be 2,303,000 gallons. A portion of the water, from Upper Floridan Aquifer wells, was treated and used for on-Property irrigation.

The Former South Lagoon and Process Area groundwater drain pumps were turned off for approximately 9 hours to pump and clean clarifiers and to treat backwash water. Pumps were off for an additional 16 hrs to clean a clogged clarifier line.

3. Plans, Reports, Deliverables and Procedures Completed:

- Remedial Design/Remedial Action Status Update Meeting (EPA/Beazer) February 23, 2018.
- Submitted version 2 of *Phase II Results for the Former South Lagoon Preliminary Design and Design Investigation Workplan Implementation* on February 26.
- Periodic maintenance checks and inspections.
- Treatment-plant component maintenance and repair as needed (caustic pump, carbon vessel gaskets and gauges, sludge pump diverter valve, bag filter vessel). Repaired plant plumbing, repaired plant electrical systems, flushed chemical lines and filters, replaced broken plant pipe channels and clamps, clean out and drum plant sump sludge, repair filter press and pump, repair blocked chemical line, jet clean clarifier effluent line, repair eye wash station.
- Irrigation breakthrough sampling February 28, 2018.
- First quarter sampling event February 12- 23, 2018.
- Located and shut off potable water leak on unused line. Will not be repaired.
- Replace EW-10 flow meter and flush lines.
- On-property irrigation using treated groundwater from FW-21B, FW-31BE, and FW-32BE.

4. Upcoming Actions:

- Second quarter sampling event May 14 - 18, 2018.
- NAPL collection at Upper Hawthorn monitoring wells: bi-weekly.
- NAPL collection at temporary Upper Hawthorn ISGS injection points: bi-weekly.
- Routine inspection, operation, maintenance, and monitoring.

5. Schedule Status:

- The project schedule is attached to the March 2018 report.

6. Community Involvement:

- Future community involvement activities will be coordinated with EPA.

Table 1. DNAPL recovery volume (gal) at wells and at Drip Track TIP: Feb 2018

Date	Well	Volume (gal)
2/1/2018	HG-10S	Stain
	HG-10D	Stain
	HG-12S	0.3
	HG-12D	ND
	HG-16S	Stain
	HG-16D	Stain
	MW-22B	Stain
2/15/2018	HG-10S	Stain
	HG-10D	Stain
	HG-12S	0.4
	HG-12D	ND
	HG-16S	0.4
	HG-16D	Stain
	MW-22B	Stain
2/6/2018	Drip Track	0.4
2/20/2018	Drip Track	0.5