

From: [Taylor, Mark](#)
To: [Wayne Reiber](#)
Cc: [John Mousa](#)
Subject: Odors at Cabot Remediation System
Date: Thursday, August 23, 2012 3:36:52 PM

Hi Wayne & John

We inspected the lift station today along with the sumps and trench line. No issues were identified. Odor around the lift station was very minimal, even with very heavy humid air. The odor control filters were changed this week and are changed weekly.

We will continue to more closely monitor this issue in the coming weeks.

Mark

Weston Solutions, Inc.
94072 Summer Breeze Drive
Fernandina Beach, FL 32034

-

[Phone: 904-261-3085](tel:904-261-3085)

Cell: 904-557-8353

Fax 904-491-5972

CONFIDENTIALITY: This email and attachments may contain information which is confidential and proprietary. Disclosure or use of any such confidential or proprietary information without the written permission of Weston Solutions, Inc. is strictly prohibited. If you received this email in error, please notify the sender by return e-mail and delete this email from your system. Thank you.

From: John Mousa
To: ["Wayne Reiber"](#)
Cc: [Taylor, Mark](#)
Subject: RE: Lift Station Odors Will Inspect Tomorrow (Thursday 8-23-2012)
Date: Wednesday, August 22, 2012 3:17:00 PM

Wayne and Mark,

Someone may need to take a walk along the entire length of the Main Street treatment trench system to see if there are any unusual odors from anywhere along the system. Not sure that the odor complaint was just localized to the area near the lift station.

John

John J. Mousa, Ph.D.
Alachua County Environmental Protection Department
408 W. University Avenue, Suite 106
Gainesville, FL 32601
Phone: 352-264-6805 Fax: 352-264-6852
jjm@alachuacounty.us

From: Wayne Reiber [<mailto:wayne.reiber@cabotcorp.com>]
Sent: Wednesday, August 22, 2012 3:14 PM
To: John Mousa
Subject: FW: Lift Station Odors Will Inspect Tomorrow (Thursday 8-23-2012)

FYI—I'll let you know what I hear. Wayne

From: Taylor, Mark [<mailto:Mark.Taylor@WestonSolutions.com>]
Sent: Wednesday, August 22, 2012 3:12 PM
To: Wayne Reiber
Subject: Lift Station Odors Will Inspect Tomorrow (Thursday 8-23-2012)

Wayne,

I spoke with Bill Campbell today regarding the complaint about lift station odors. He will make a visit to the lift station tomorrow (Thursday) and see if there is anything unusual going on.

Mark

Weston Solutions, Inc.
94072 Summer Breeze Drive
Fernandina Beach, FL 32034

[Phone: 904-261-3085](tel:904-261-3085)
Cell: 904-557-8353
Fax 904-491-5972

CONFIDENTIALITY: This email and attachments may contain information which is confidential and proprietary. Disclosure or use of any such confidential or proprietary information without the written permission of Weston Solutions, Inc. is strictly prohibited. If you received this email in error, please notify the sender by return e-mail and delete this email from your system. Thank you.

This e-mail and any attachments are for use by the intended recipient and may contain confidential, privileged or proprietary information. Any use, dissemination, distribution, or reproduction of this message by unintended recipients is prohibited. If you have received this e-mail in error, please notify the sender immediately by telephone or e-mail and delete the original message. Thank you.